



**CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM**  
Drinking Water and Groundwater Bureau  
Water Division



**RSA/Rule:** RSA 485:3, XI, Env-Dw 303

**Water System Name:** Mountain River East Condominium Association

**Town/City:** Thornton NH

**PWS ID:**

2	3	4	2	0	4	0
---	---	---	---	---	---	---

*The owner, operator, or designee of the water system indicated above hereby confirms that the **Consumer Confidence Report (CCR) has been distributed to all water customers** as required by Env-Dw 811. Further, the owner, operator, or designee certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the New Hampshire Department of Environmental Services, Drinking Water and Groundwater Bureau.*

- CCR was distributed by:**
- Hand Delivery** (includes door-to-door)
  - check all that apply!  **Mail Delivery** (includes U.S. mailing of a paper copy)
  - Electronic Delivery** (email attachment)
  - Electronic Delivery** (website URL included on bill)

If applicable, check any of the "Good faith" efforts used to reach all consumers who may not otherwise receive it.

- Delivery of multiple copies to apartments, businesses, schools, nursing homes and large private employers.
- Publication of CCR in local newspaper.
- Mail the CCR to postal patrons within the service area.
- Posting the CCR in public places.
- Advertising availability of the CCR in news media.
- Posting the CCR on the internet/ social media.
- Delivery to community organizations.

**Date(s) CCR Distributed:** 3/17/25

**Certified by:** Signature: Guy P. Tuchon Date: 3/17/25  
 Print Name: Guy P. Tuchon

**NOTE** the following:

- Mail or directly deliver copies of the current CCR to each customer **by July 1** (keep a copy for your records).
- Submit a copy of the CCR to NHDES **by July 1** to [dwmonitoring@des.nh.gov](mailto:dwmonitoring@des.nh.gov)
- Submit this completed certification form to NHDES **within 10 days of distributing the CCR**, but in no event later than July 10, to [dwmonitoring@des.nh.gov](mailto:dwmonitoring@des.nh.gov).
  - ▶ **The "Certified by" signature must be dated on or after the "Date(s) CCR Distributed".**
- It is recommended that you send the CCR and Certification to NHDES at the same time to ensure that all actions are completed on time.
- The CCR and certification form should be mailed to the following address if unable to send via email.

Consumer Confidence Report  
 NHDES Drinking Water and Groundwater Bureau  
 29 Hazen Drive, PO Box 95, Concord, NH 03302-0095  
 Fax: (603) 271-5171

# 2025 Consumer Confidence Report

## Mountain River East Condominium Association

2342040


### Introduction

As a responsible public water system (PWS), our mission is to keep the well house maintained / up to date. Aging infrastructure presents challenges for maintaining safe quality drinking water and continuous improvements are necessary. In the past year, we have begun/completed Well house updates. In the coming year we intend to Plan to maintain all updates. These investments along with on-going operation and maintenance costs are supported by Mountain River East Condo Association / Approved by Board of Directors. When considering the high value placed on quality drinking water, it is truly a bargain to have water service that protects public health, fights fires, supports businesses and the economy, and ensures high-quality drinking water is always available at your tap.

### What is a Consumer Confidence Report?

The Consumer Confidence Report (CCR) details the quality of your drinking water, where it comes from, and how to get more information. This annual report documents all detected primary and secondary drinking water contaminants and their respective standards known as Maximum Contaminant Levels (MCLs).

NOW IT COMES WITH A LIST OF INGREDIENTS.



**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present** in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including per- and polyfluoroalkyl substances, synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The US Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

### What is the source of my drinking water?

*Mountain River East Condo Association from 2 bedrock wells bedrock well 1 is 654 feet deep And yields 15 gallons per minute. Bedrock well 2 is 525 feet deep and*

*yields 20 gallons a minute. Water flows to 3600 gallon tank , duplicate booster pumps then transfers the water as its used to owners. The water is not treated and provided to 80 units / owners at Mountain River East Condominium Association*

### Why are contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

### Source Water Assessment Summary

NHDES prepared drinking water source assessment reports for all public water systems between 2000 and 2003 in an effort to assess the vulnerability of each of the state's public water supply sources. Included in the report is a map of each source water protection area, a list of potential and known contamination sources, and a summary of available protection options. The results of the assessment, prepared on 5/8/2001 are noted below, if an assessment was completed. **MRE 2 susceptibility factors were rated high 1 was rated medium 9 rated low**

Note: Due to the year the assessment was completed, some of the ratings may be different if updated to reflect current information.

The complete Assessment Report is available for review at [Melissa@madriverrproperty.com](mailto:Melissa@madriverrproperty.com) For more information, call *Guy Tuchon Water Operator* 603-254-7256 or visit the [NHDES website](#).

#### How can I get involved?

*Mountain River East Condo Association Meetings*

For more information about your drinking water, please call *The Board of Directors* or *Guy Tuchon Water Operator* 603-254-7256. Although we do not have specific dates for public participation events, feel free to contact us with your questions."

#### Ambient Groundwater Quality Standard or AGQS:

The maximum concentration levels for contaminants in groundwater that are established under RSA 485-C, the Groundwater Protection Act.

**Action Level or AL:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Level I Assessment:** A study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system

**Level II Assessment:** A very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level or MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Treatment Technique or TT:** A required process intended to reduce the level of a contaminant in drinking water.

#### Abbreviations

BDL: Below Detection Limit

NA: Not Applicable

ND: Not Detectable at testing limits

NTU: Nephelometric Turbidity Unit

pCi/L: picoCurie per Liter

ppb: parts per billion OR ug/L: micrograms per Liter

ppm: parts per million OR mg/L: milligrams per Liter

RAA: Running Annual Average

TTHM: Total Trihalomethanes

UCMR: Unregulated Contaminant Monitoring Rule

#### Drinking Water Contaminants:

**Lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water system is responsible for high quality drinking water but cannot control the variety of materials used in your plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing cold water from your tap for at least 30 seconds before using water for drinking or cooking. Do not use hot water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water

tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at [US EPA Basic Information about Lead in Drinking Water](#)

**Health Effects of Lead Exposure** to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.


# MOUNTAIN RIVER EAST CONDOMINIUM ASSOCIATION

## 2025 Report (2024 Data) 2342040

LEAD AND COPPER							
Contaminant (Units)	Action Level (AL)	90 <sup>th</sup> percentile sample value *	Date	# of sites above AL	Violation No	Likely Source of Contamination	Health Effects of Contaminant
Copper (ppm)	.005	—	2/7/2004	Site 4	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
Lead (ppb)	.001					Corrosion of household plumbing systems, erosion of natural deposits	(15 ppb in more than 5%) Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791). (Above 15 ppb) Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

**Health Effects of Lead** Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

# HOUSEHOLD HAZARDOUS WASTE AND YOUR DRINKING WATER



**What Is Household Hazardous Waste?** Chemicals typically found in homes, such as:  
Gasoline • Antifreeze • Oil-Based Paints • Drain Cleaners • Pesticides • Furniture Strippers  
Oven Cleaners • Disinfectants • Kerosene • Spot Removers • Used Motor Oil • Auto Batteries



**Why Should You Be Concerned?** Some household hazardous wastes can injure you, your family, or your pets; damage the environment; or contaminate drinking water supplies. The groundwater in your area flows to a public drinking water supply, and we're asking for your help in keeping it clean and safe. If you have a well on your property, you also need to think about keeping the groundwater that supplies *your* well clean and safe to drink.

**What Should You Do?** *Bring your household hazardous waste to one of your community's household hazardous waste collection events\* (August and September).*

**For information about one of your area's collection events, contact:**

**Pemi-Baker Solid Waste District**

(603) 444-6303 EXT 2019

**Click here for event information:** <http://www.nccouncil.org/services/solid-waste/household-hazardous-waste-other-special-collections/>

**Participating Communities:** Ashland, Campton, Danbury, Dorchester, Easton, Ellsworth, Franconia, Groton, Landaff, Lisbon, Littleton, Lyman, Plymouth, Rumney, Sugar Hill, Thornton, Warren, Waterville Valley, and Wentworth.

**There are limits on what you can bring and how much so be sure to check out the website above for more information, including dates, times, and locations of collection events.**

**For more information about Household Hazardous Waste Collection (HHW) call DES at 271-2047 or visit our household hazardous waste website at: <https://www.des.nh.gov/waste/household-hazardous-waste>**

\* Funding assistance provided by NH Department of Environmental Services.



**ANALYTICAL RESULTS**

**Batch ID/Form:** 290202 - CHEMICAL MONITORING

**Submitting Lab ID:** 1012

**PWS ID/Name:** 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

**Report Date:** 12/18/2024

**Collector:** GUY P. TUCHON

**Phone:** 603-254-7256

**Collect Date:** 11/25/2024 12:30:00

**Lab Sample ID:** 290202\_410-198994

**Matrix:** WATER

**Received:** 11/25/2024 15:24:00

**Sample Location ID:** 000

**Sample Type:** ROUTINE-SAMPLE

**Compliance Period:** Q4 2024

**Description:** DEP SAMPLING TAP/PUMPHOUSE /BLEND 001 002

**Receipt Temp.:** 3.2 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method:</b> 537.1		<b>Analyzing Lab:</b> 2730-EUROFINS LANCASTER LABORATORIES ENVIRONMENT TESTING LLC							
PERFLUOROHXANE SULFONIC ACID - PFHXS	ND	NG/L	1.6	1	12/05/2024 00:00:00	12/09/2024 18:54:00	355-46-4		
PERFLUORONONANOIC ACID - PFNA	ND	NG/L	1.6	1	12/05/2024 00:00:00	12/09/2024 18:54:00	375-95-1		
PERFLUOROOCTANE SULFONIC ACID - PFOS	ND	NG/L	1.6	1	12/05/2024 00:00:00	12/09/2024 18:54:00	1763-23-1		
PERFLUOROOCTANOIC ACID - PFOA	ND	NG/L	1.6	1	12/05/2024 00:00:00	12/09/2024 18:54:00	335-67-1		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.



**ANALYTICAL RESULTS**

**Batch ID/Form:** B408961 - CHEMICAL MONITORING

**Submitting Lab ID:** 3000

**PWS ID/Name:** 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

**Report Date:** 12/20/2024

**Collector:** GUY TUCHON

**Phone:** 603-254-7256

**Collect Date:** 11/25/2024 12:30:00

**Lab Sample ID:** B408961002

**Matrix:** WATER

**Received:** 11/25/2024 15:30:00

**Sample Location ID:** 000

**Sample Type:** ROUTINE-SAMPLE

**Compliance Period:** Q4 2024

**Description:** DEP SAMPLING TAP/PUMPHOUSE /BLEND 001 002

**Receipt Temp.:** 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method: 504.1</b>		<b>Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES</b>							
1,2-DIBROMO-3-CHLOROPROPANE (DBCP)	ND	UG/L	.02		00:00:00	12/06/2024 04:19:00	96-12-8		
ETHYLENE DIBROMIDE (EDB)	ND	UG/L	.02		00:00:00	12/06/2024 04:19:00	106-93-4		
<b>Analytical Method: 505</b>		<b>Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES</b>							
CHLORDANE (TECH.)	ND	UG/L	.2		00:00:00	12/06/2024 04:19:00	12789-03-6		
TOXAPHENE (CHLORINATED CAMPHENE)	ND	UG/L	3		00:00:00	12/06/2024 04:19:00	8001-35-2		
<b>Analytical Method: 524.2</b>		<b>Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES</b>							
1,1,1,2-TETRACHLOROETHANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	630-20-6		
1,1,1-TRICHLOROETHANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	71-55-6		
1,1,2,2-TETRACHLOROETHANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	79-34-5		
1,1,2-TRICHLOROETHANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	79-00-5		
1,1-DICHLOROETHANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	75-34-3		
1,1-DICHLOROETHYLENE (DCE)	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	75-35-4		
1,1-DICHLOROPROPENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	563-58-6		
1,2,3-TRICHLOROBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	87-61-6		
1,2,3-TRICHLOROPROPANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	96-18-4		
1,2,4-TRICHLOROBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	120-82-1		
1,2,4-TRIMETHYLBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	95-63-6		
1,2-DICHLOROBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	95-50-1		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.



**ANALYTICAL RESULTS**

**Batch ID/Form:** B408961 - CHEMICAL MONITORING

**Submitting Lab ID:** 3000

**PWS ID/Name:** 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

**Report Date:** 12/20/2024

**Collector:** GUY TUCHON

**Phone:** 603-254-7256

**Collect Date:** 11/25/2024 12:30:00

**Lab Sample ID:** B408961002

**Matrix:** WATER

**Received:** 11/25/2024 15:30:00

**Sample Location ID:** 000

**Sample Type:** ROUTINE-SAMPLE

**Compliance Period:** Q4 2024

**Description:** DEP SAMPLING TAP/PUMPHOUSE /BLEND 001 002

**Receipt Temp.:** 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method: 524.2</b>		<b>Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES</b>							
CARBON DISULFIDE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	75-15-0		
CARBON TETRACHLORIDE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	56-23-5		
CHLOROBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	108-90-7		
CHLOROETHANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	75-00-3		
CHLOROFORM	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	67-66-3		
CHLOROMETHANE (METHYL CHLORIDE)	ND	UG/L	2		00:00:00	12/02/2024 13:44:00	74-87-3		
CIS-1 2-DICHLOROETHYLENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	156-59-2		
CIS-1,3-DICHLOROPROPENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	10061-01-5		
DI-ISOPROPYLETHER (DIPE)	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	108-20-3		
DIBROMOCHLOROMETHANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	124-48-1		
DIBROMOMETHANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	74-95-3		
DICHLORODIFLUOROMETHANE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	75-71-8		
DICHLOROMETHANE (METHYLENE CHLORIDE)	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	75-09-2		
DIETHYL ETHER	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	60-29-7		
ETHYL - T- BUTYL ETHER (ETBE)	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	637-92-3		
ETHYLBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	100-41-4		
HEXACHLOROBUTADIENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	87-68-3		
ISOPROPYLBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	98-82-8		
M/P-XYLENE	ND	UG/L	1		00:00:00	12/02/2024 13:44:00	108-38-3/106-42		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.



**ANALYTICAL RESULTS**

Batch ID/Form: B408961 - CHEMICAL MONITORING

Submitting Lab ID: 3000

PWS ID/Name: 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

Report Date: 12/20/2024

Collector: GUY TUCHON

Phone: 603-254-7256

Collect Date: 11/25/2024 12:30:00

Lab Sample ID: B408961002

Matrix: WATER

Received: 11/25/2024 15:30:00

Sample Location ID: 000

Sample Type: ROUTINE-SAMPLE

Compliance Period: Q4 2024

Description: DEP SAMPLING TAP/PUMPHOUSE /BLEND 001 002

Receipt Temp.: 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 524.2		Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES							
METHYL ETHYL KETONE (MEK)	ND	UG/L	10		00:00:00	12/02/2024 13:44:00	78-93-3		
METHYL TERT-BUTYL ETHER (MTBE)	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	1634-04-4		
N-BUTYLBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	104-51-8		
N-PROPYLBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	103-65-1		
NAPHTHALENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	91-20-3		
O-XYLENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	95-47-6		
P-ISOPROPYLTOLUENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	99-87-6		
SEC-BUTYLBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	135-98-8		
STYRENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	100-42-5		
TERT-AMYL METHYL ETHER (TAME)	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	994-05-8		
TERT-BUTYL ALCOHOL (TBA)	ND	UG/L	10		00:00:00	12/02/2024 13:44:00	75-65-0		
TERT-BUTYLBENZENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	98-06-6		
TETRACHLOROETHYLENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	127-18-4		
TETRAHYDROFURAN (THF)	ND	UG/L	10		00:00:00	12/02/2024 13:44:00	109-99-9		
TOLUENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	108-88-3		
TRANS-1,2-DICHLOROETHYLENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	156-60-5		
TRANS-1,3-DICHLOROPROPENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	10061-02-6		
TRICHLOROETHYLENE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	79-01-6		
TRICHLOROFLUOROMETHAN E (CFC-11)	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	75-69-4		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.



**ANALYTICAL RESULTS**

Batch ID/Form: B408961 - CHEMICAL MONITORING

Submitting Lab ID: 3000

PWS ID/Name: 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

Report Date: 12/20/2024

Collector: GUY TUCHON

Phone: 603-254-7256

Collect Date: 11/25/2024 12:30:00

Lab Sample ID: B408961002

Matrix: WATER

Received: 11/25/2024 15:30:00

Sample Location ID: 000

Sample Type: ROUTINE-SAMPLE

Compliance Period: Q4 2024

Description: DEP SAMPLING TAP/PUMPHOUSE /BLEND 001 002

Receipt Temp.: 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method: 524.2</b>		<b>Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES</b>							
VINYL CHLORIDE	ND	UG/L	.5		00:00:00	12/02/2024 13:44:00	75-01-4		
XYLENES, TOTAL	ND	UG/L	1.5		00:00:00	12/02/2024 13:44:00	1330-20-7		
<b>Analytical Method: 525.2</b>		<b>Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES</b>							
2,2',3',4,6-PENTACHLOROBIPHENYL	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	60233-25-2		
2,2',3,3',4,4',6-HEPTACHLOROBIPHENYL	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	52663-71-5		
2,2',3,3',4,5',6,6'-OCTACHLOROBIPHENYL	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	40186-71-8		
2,2',4,4',5,6'-HEXACHLOROBIPHENYL	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	60145-22-4		
2,2',4,4'-TETRACHLOROBIPHENYL	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	2437-79-8		
2,3-DICHLOROBIPHENYL	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	16605-91-7		
2,4,5-TRICHLOROBIPHENYL	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	15862-07-4		
2-CHLOROBIPHENYL	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	2051-60-7		
2-METHYLNAPHTHALENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	91-57-6		
4,4-DDD	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	72-54-8		
4,4-DDE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	72-55-9		
4,4-DDT	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	50-29-3		
ACENAPHTHENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	83-32-9		
ACENAPHTHYLENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	208-96-8		
ALACHLOR	ND	UG/L	.2		12/03/2024 09:38:00	12/10/2024 01:46:00	15972-60-8		
ALDRIN	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	309-00-2		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.



**ANALYTICAL RESULTS**

Batch ID/Form: B408961 - CHEMICAL MONITORING

Submitting Lab ID: 3000

PWS ID/Name: 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

Report Date: 12/20/2024

Collector: GUY TUCHON

Phone: 603-254-7256

Collect Date: 11/25/2024 12:30:00

Lab Sample ID: B408961002

Matrix: WATER

Received: 11/25/2024 15:30:00

Sample Location ID: 000

Sample Type: ROUTINE-SAMPLE

Compliance Period: Q4 2024

Description: DEP SAMPLING TAP/PUMPHOUSE /BLEND 001 002

Receipt Temp.: 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method: 525.2</b>		<b>Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES</b>							
ALPHA-CHLORDANE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	5103-71-9		
ANTHRACENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	120-12-7		
ATRAZINE	ND	UG/L	.2		12/03/2024 09:38:00	12/10/2024 01:46:00	1912-24-9		
BENZO(A)ANTHRACENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	56-55-3		
BENZO(A)PYRENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	50-32-8		
BENZO(B)FLUORANTHENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	205-99-2		
BENZO(G,H,I)PERYLENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	191-24-2		
BENZO(K)FLUORANTHENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	207-08-9		
BENZYL BUTYL PHTHALATE	ND	UG/L	1		12/03/2024 09:38:00	12/10/2024 01:46:00	85-68-7		
BIS(2-ETHYLHEXYL) ADIPATE	ND	UG/L	1		12/03/2024 09:38:00	12/10/2024 01:46:00	103-23-1		
BIS(2-ETHYLHEXYL) PHTHALATE	ND	UG/L	1		12/03/2024 09:38:00	12/10/2024 01:46:00	117-81-7		
BUTACHLOR	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	23184-66-9		
CHRYSENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	218-01-9		
DI-N-BUTYL PHTHALATE	ND	UG/L	1		12/03/2024 09:38:00	12/10/2024 01:46:00	84-74-2		
DIBENZO(A,H)ANTHRACENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	53-70-3		
DIELDRIN	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	60-57-1		
DIETHYL PHTHALATE	ND	UG/L	1		12/03/2024 09:38:00	12/10/2024 01:46:00	84-66-2		
DIMETHYL PHTHALATE	ND	UG/L	1		12/03/2024 09:38:00	12/10/2024 01:46:00	131-11-3		
ENDRIN	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	72-20-8		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.



**ANALYTICAL RESULTS**

Batch ID/Form: B408961 - CHEMICAL MONITORING

Submitting Lab ID: 3000

PWS ID/Name: 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

Report Date: 12/20/2024

Collector: GUY TUCHON

Phone: 603-254-7256

Collect Date: 11/25/2024 12:30:00

Lab Sample ID: B408961002

Matrix: WATER

Received: 11/25/2024 15:30:00

Sample Location ID: 000

Sample Type: ROUTINE-SAMPLE

Compliance Period: Q4 2024

Description: DEP SAMPLING TAP/PUMPHOUSE /BLEND 001 002

Receipt Temp.: 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method: 525.2</b>		<b>Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES</b>							
ENDRIN ALDEHYDE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	7421-93-4		
FLUORANTHENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	206-44-0		
FLUORENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	86-73-7		
GAMMA-BHC (LINDANE)	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	58-89-9		
GAMMA-CHLORDANE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	5103-74-2		
HEPTACHLOR	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	76-44-8		
HEPTACHLOR EPOXIDE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	1024-57-3		
HEXACHLOROBENZENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	118-74-1		
HEXACHLOROCYCLOPENTADIENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	77-47-4		
INDENO(1,2,3-CD)PYRENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	193-39-5		
ISOPHORONE	ND	UG/L	.2		12/03/2024 09:38:00	12/10/2024 01:46:00	78-59-1		
METHOXYCHLOR	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	72-43-5		
METOLACHLOR	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	51218-45-2		
METRIBUZIN	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	21087-64-9		
NAPHTHALENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	91-20-3		
PENTACHLOROPHENOL	ND	UG/L	.4		12/03/2024 09:38:00	12/10/2024 01:46:00	87-86-5		
PHENANTHRENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	85-01-8		
PROPACHLOR	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	1918-16-7		
PYRENE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	129-00-0		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.



**ANALYTICAL RESULTS**

Batch ID/Form: B408961 - CHEMICAL MONITORING

Submitting Lab ID: 3000

PWS ID/Name: 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

Report Date: 12/20/2024

Collector: GUY TUCHON

Phone: 603-254-7256

Collect Date: 11/25/2024 12:30:00

Lab Sample ID: B408961002

Matrix: WATER

Received: 11/25/2024 15:30:00

Sample Location ID: 000

Sample Type: ROUTINE-SAMPLE

Compliance Period: Q4 2024

Description: DEP SAMPLING TAP/PUMPHOUSE /BLEND 001 002

Receipt Temp.: 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
---------	---------	-------	-----	----	---------------	---------------	--------------	---------	-------

Analytical Method: 525.2

Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES

SIMAZINE	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	122-34-9		
TRANS-NONACHLOR	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	39765-80-5		
TRIFLURALIN	ND	UG/L	.1		12/03/2024 09:38:00	12/10/2024 01:46:00	1582-09-8		

Analytical Method: 531.2

Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES

3-HYDROXYCARBOFURAN	ND	UG/L	1		00:00:00	12/11/2024 00:24:00	16655-82-6		
ALDICARB	ND	UG/L	1		00:00:00	12/11/2024 00:24:00	116-06-3		
ALDICARB SULFONE	ND	UG/L	1		00:00:00	12/11/2024 00:24:00	1646-88-4		
ALDICARB SULFOXIDE	ND	UG/L	1		00:00:00	12/11/2024 00:24:00	1646-87-3		
CARBARYL	ND	UG/L	1		00:00:00	12/11/2024 00:24:00	63-25-2		
CARBOFURAN	ND	UG/L	1		00:00:00	12/11/2024 00:24:00	1563-66-2		
METHOMYL	ND	UG/L	1		00:00:00	12/11/2024 00:24:00	16752-77-5		
OXAMYL (VYDATE)	ND	UG/L	1		00:00:00	12/11/2024 00:24:00	23135-22-0		

Analytical Method: 547

Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES

GLYPHOSATE	ND	UG/L	25		00:00:00	12/05/2024 12:17:00	1071-83-6		
------------	----	------	----	--	----------	------------------------	-----------	--	--

Analytical Method: 549.2

Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES

DIQUAT	ND	UG/L	2.5		11/27/2024 11:41:00	11/27/2024 12:47:00	2764-72-9		
--------	----	------	-----	--	------------------------	------------------------	-----------	--	--

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.



**ANALYTICAL RESULTS**

Batch ID/Form: B408961 - CHEMICAL MONITORING

Submitting Lab ID: 3000

PWS ID/Name: 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

Report Date: 12/20/2024

Collector: GUY TUCHON

Phone: 603-254-7256

Collect Date: 11/25/2024 12:30:00

Lab Sample ID: B408961002

Matrix: WATER

Received: 11/25/2024 15:30:00

Sample Location ID: 000

Sample Type: ROUTINE-SAMPLE

Compliance Period: Q4 2024

Description: DEP SAMPLING TAP/PUMPHOUSE /BLEND 001 002

Receipt Temp.: 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method: 555</b>		<b>Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES</b>							
2,4,5-TP (SILVEX)	ND	UG/L	1		00:00:00	11/26/2024 02:03:00	93-72-1		
2,4-D	ND	UG/L	1		00:00:00	11/26/2024 02:03:00	94-75-7		
ACIFLUORFEN	ND	UG/L	1		00:00:00	11/26/2024 02:03:00	50594-66-6		
DICAMBA	ND	UG/L	1		00:00:00	11/26/2024 02:03:00	1918-00-9		
DINOSEB (2-SEC-BUTYL-4 6-DINITROPHENOL DNBP)	ND	UG/L	.5		00:00:00	11/26/2024 02:03:00	88-85-7		
PICLORAM	ND	UG/L	1		00:00:00	11/26/2024 02:03:00	1918-02-1		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.



**ANALYTICAL RESULTS**

**Batch ID/Form:** B400514 - LEAD AND COPPER RULE

**Submitting Lab ID:** 3000

**PWS ID/Name:** 2342040 - MOUNTAIN RIVER CONDOS EAST - THORNTON

**Report Date:** 02/16/2024

**Collector:** GUY TUCHON

**Phone:** 603-254-7256

**Collect Date:** 02/05/2024 08:00:00

**Lab Sample ID:** B400514001

**Matrix:** WATER

**Received:** 02/05/2024 11:43:00

**Sample Location ID:** 001

**Sample Type:** ROUTINE-SAMPLE

**Compliance Period:** Q1 2024

**Description:** UNIT 4

**Receipt Temp.:** 7 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method:</b> 200.8		<b>Analyzing Lab:</b> 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES							
COPPER, TOTAL	ND	MG/L	.005		02/07/2024 11:15:00	02/08/2024 13:19:00	7440-50-8		
LEAD, TOTAL	ND	MG/L	.001		02/07/2024 11:15:00	02/08/2024 13:19:00	7439-92-1		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.